

ITT

Wastewater

CentriPro

Customized Control Panel Specification

GENERAL

- Furnish and install CentriPro Customized Control Panel Part No. _____. Panel rated for _____ hp, _____ volts, _____ phase power supply. Panel shall be used in installation _____ (location).

QUALIFICATIONS


All panel manufacturers must be pre-qualified by the engineer in order to qualify as acceptable manufacturers. Pre-qualification shall be no later than two (2) weeks prior to published bid date for this project. Failure to pre-qualify will be grounds for disqualification after the bid opening date. All decisions of qualification shall reside with the engineer of record at time of bidding.

PANEL DESIGN

Duplex Control panel to operate up to 5 hp 208 volt, 3 phase pumps, Nema 1 (indoor) enclosure, pump motor fused disconnects, control circuit breaker, control circuit transformer, motor starters with overloads, H-O-A's and run lights, duplex alternation, 24 VAC float control circuit, high level alarm with bell, dry alarm contacts.

LISTINGS

Panel shall be UL listed. Panels that are not UL listed will not be considered equal.



CentriPro®

CentriPro is a brand of ITT Corporation.

www.centripro.com

Engineered for life



ITT

Wastewater



CentriPro and the ITT Engineered Blocks Symbol are registered trademarks and tradenames of ITT Corporation.

SPECIFICATIONS ARE SUBJECT TO CHANGE WITHOUT NOTICE.

BCPPANELSPEC September, 2007

© 2007 ITT Corporation

Engineered for life